

**API/IP-1581 5th Edition Completed Tests
Velcon Filters, Inc.**

Date	Test Vessel	Flow Rate (GPM)	Category, API/IP 1581 5th Edition	Coalescers	Separators	3rd Stage
Oct-03	R11 OshKosh	600	M - New & Existing Equipment	15 x I-440MM	15 x SI-542	N/A
Sep-03	VV4256	2500	C - New & Existing Equipment	18 x I-654C5TB	8 x SO-646V5	N/A
Jul-03	HV2856	1000	C - New & Existing Equipment	7 x I-656C5TB	2 x SO-648CM	N/A
Jun-03	HV2856M	1312	C - Existing Equipment	7 x I-656C5TB	2 x SO-648V	N/A
Jun-03	VV2752B	900	C - New & Existing Equipment	7 x I-644C5TB	3 x SO-644V5	N/A
Apr-03	AAE	2000	M - New & Existing Equipment	50 x I-620MM	20 x SO-620C	N/A
Dec-02	HVS2628M 3-Stage	600	M100 - New & Existing Equipment	10 x I-628A4TB	8 x SO-616GS	40 x CDF-215
Nov-02	HV2856	1000	M100 - New & Existing Equipment	7 X I-656A4TB	2 X SO-648CM	N/A